



NOTES:

1. THE TEST LEAD WIRES SHALL BE STRANDED COPPER AWG WIRE WITH TW, THW, OR THWN INSULATION. WIRE SIZE AND COLOR SHALL BE AS SHOWN.
2. RUN ALL WIRES IN 2" PVC SCH. 40 FROM THE CONNECTION POINT UNTIL THEY REACH THE BOTTOM OF TEST STATION ASSEMBLY.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21

Mike Harmon

Chief Engineer

STANDARD DETAIL

TEST STATION AT
MECHANICAL JOINT / PUSH-ON
CAP / PLUG

$\frac{C}{2.6}$