



#### NOTES:

1. DO NOT ATTACH PIPE OR FITTINGS TO THE WELDED-ON CONNECTION UNTIL MAINLINE PIPE WITH THE CONNECTION IS SUPPORTED IN PLACE.
2. SUPPORT ALL PIPING ATTACHED TO THE WELDED-ON CONNECTION IMMEDIATELY AFTER INSTALLATION TO MINIMIZE LOAD TRANSMISSION TO THE CONNECTION.
3. RESTRAIN ALL JOINTS ON BLOWOFF PIPING, SEE SPECIFICATIONS.
4. FOR PIPE EMBEDMENT REQUIREMENTS FOR MAINLINE PIPE, SEE DETAIL M/8.1a AND M/8.1b.

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED: 7-26-21

*M. H. Harnum*  
Chief Engineer

STANDARD DETAIL

WELDED-ON CONNECTION  
FOR BLOWOFFS ON  
MAINS 36-INCH AND LARGER

W  
3.06