



NOTES:

1. PRECAST CONCRETE $f'_c=5000$ PSI @ 28 DAYS.
2. REINFORCEMENT SHALL CONFORM TO ASTM C-478.

ADJUSTING GRADE RING SIZE
2" X 3"
2" 1/2" X 3 1/2"
3" X 4"

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 2-7-21
Mike Hammer
Chief Engineer

STANDARD DETAIL
24-INCH PRECAST CONCRETE
MANHOLE SLOPED
TRANSITION RING

S
4.22