



ELEVATION

NOTES

1. RESTRAIN ALL JOINTS ON PRESSURE RELIEF PIPING, SEE DETAIL W/4.8 NOTE 4.
2. SEE DRAWINGS FOR PROFILE OF PRESSURE RELIEF PIPING. PROVIDE CONTINUOUS POSITIVE DRAINAGE AT 1.0% SLOPE MINIMUM TOWARD HEADWALL/FLAP VALVE FOR ANY PORTION OF PRESSURE RELIEF PIPING HAVING LESS THAN 4' OF COVER.
3. ONLY DUCTILE IRON PIPE AND FITTINGS.
4. V-BIO POLYETHYLENE ENCASEMENT FOR ALL DUCTILE IRON PIPE AND FITTINGS. SEE DETAIL W/2.8 AT CONCRETE INTERFACE.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21

M. H. Harmer

Chief Engineer

STANDARD DETAIL

ENDWALL FOR
PRESSURE RELIEF VALVE PIPING

W
4.6