



NOTES:

1. USE INSULATORS ON 1", 1 1/2", AND 2" COPPER PIPE HOUSE CONNECTIONS.
2. USE INSULATOR ON COPPER PIPE TAPPED ON CAST IRON OR DUCTILE IRON PIPES,

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21
Mike Harmon
Chief Engineer

STANDARD DETAIL
INSULATED JOINT
FOR COPPER PIPE SERVICE
CONNECTIONS (2" OR LESS)

$\frac{C}{3.5}$