



NOTES:

1. SHC AT PROPERTY SHALL TERMINATE IN ACCORDANCE WITH DETAIL S/6.8.
2. CONCRETE ENCASUREMENT NOT REQUIRED FOR DUCTILE IRON WYE ON BEND. SEE NOTE AND DETAIL S/6.8
3. SEE CONNECTION TO SEWER MAIN NOTES, DETAIL S/6.0.
4. ORIENT T-WYE AS SHOWN WITH RESPECT TO FLOW.
5. ALL DIP SHALL BE MIN. CL.54
6. ALL DIP SHALL HAVE SPECIAL INTERIOR COATING, SEE SPECIFICATIONS.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-7-21
Mike Harmon
Chief Engineer

STANDARD DETAIL
4-INCH AND 6-INCH
DIP OR PVC AWWA C900
HOUSE CONNECTIONS
AND FITTINGS

S
6.3a