



NOTES:

1. SLAB THICKNESS 8".
2. REINFORCING STEEL SHALL HAVE MINIMUM 1-1/2" COVER.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-7-21

M. H. Harris

Chief Engineer

STANDARD DETAIL
PRECAST TOP SLAB
FOR 48-INCH AND
60-INCH DIAMETER
PRECAST CONCRETE MANHOLES

S
1.3