



NOTES:

1. TEST LEAD WIRES SHALL MEET REQUIREMENTS OF DETAIL C/3.0, NOTE 1.
2. NOTIFY FOREIGN PIPELINE COMPANY IN ADVANCE FOR PERMISSION TO ATTACH WIRES TO THEIR PIPE, OR FOR THE FOREIGN PIPELINE COMPANY TO ATTACH WIRES TO THEIR PIPELINE.
3. RUN ALL WIRES IN 2" PVC SCH40 CONDUIT FROM CONNECTION POINTS UNTIL THEY REACH THE BOTTOM OF TEST STATION ASSEMBLY.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21
M. H. Hammer
Chief Engineer

STANDARD DETAIL
TEST STATION AT
FOREIGN PIPELINE
CROSSING

C
4.7