



NOTES:

1. ANODES REQUIRED ONLY IF CROSS IS DUCTILE IRON.
2. ANODES PLACED AT SAME DEPTH AS THE BOTTOM OF PIPE AND AT A MINIMUM OF 12" FROM EDGE OF PIPE.
3. DO NOT THERMITE WELD TO PVC PIPE.
4. SEE SPECIFICATION FOR ANODE SIZE.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21
M. Hammer
Chief Engineer

STANDARD DETAIL
PVC/WWA C-900 PIPE
ANODE PROTECTION CROSS

C
7.5