



#### NOTES:

1. INSTALL W.H.C. 3'-6" MINIMUM BELOW FINISHED GRADE, UNLESS OTHERWISE SHOWN OR DIRECTED BY THE ENGINEER.
2. WHEN W.H.C. AND S.H.C. ARE INSTALLED IN SAME TRENCH, SEE DETAIL M/18.0.
3. END OF W.H.C. AT THE PROPERTY LINE. PROVIDE 4'-0" COVER OVER END OF W.H.C., UNLESS OTHER DIRECTED BY THE ENGINEER/CONTRACT MANAGER.
4. CORPORATION STOP TO BE LEFT OPEN AND CURB STOP TO STAY CLOSED.
5. AN APPROVED BENDING TOOL REQUIRED FOR MAKING BENDS IN ALL SIZES OF TYPE "K" COPPER PIPE.
6. FOR CONNECTIONS TO NEW WATER PIPE, V-BIO POLYETHYLENE ENCASEMENT REQUIRED ON NEW COPPER PIPE, SEE SPECIFICATIONS.

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED: 7-26-21  
*Mike Harmon*  
Chief Engineer

STANDARD DETAIL  
1-INCH, 1-1/2-INCH AND 2-INCH  
WATER HOUSE CONNECTIONS  
FOR INSIDE METERS

W  
5.10