



SECTION A-A

18" LENGTH OF 1" GALVANIZED PIPE
CENTERED IN BOTH BRACE EYES.

2" TYPE K COPPER

YOKE TIE BAR

24" DIAMETER TAPERED PLASTIC
METER BOX, 30" LENGTH

1" METER (BY OTHERS)

1-1/2" TYPE K COPPER

1-1/2" OUTLET
CAP (TYPICAL)

1" METER (BY OTHERS)

PLAN

NOTES:

1. METER SETTING FOR NON-TRAFFIC AREAS ONLY, DO NOT LOCATE IN SIDEWALK OR DRIVEWAY, UNLESS OTHERWISE NOTED ON THE DRAWINGS.
2. COMPACT BACKFILL AND AGGREGATE BASE AS STRUCTURAL FILL.
3. EXTEND COPPER SERVICE OUTLET 3'-0" MINIMUM BEYOND METER BOX AS SHOWN OR TO THE PROPERTY LINE, WHICHEVER IS GREATER.
4. 1" DOUBLE METER YOKE SETTER IS COMPLETE ONE-PIECE FACTORY ASSEMBLED, INCLUDING FOUR YOKE ANGLE BALL VALVES, BENDS, TWO YOKES AND COMPRESSION COUPLINGS.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 2-26-21

Mike Harmon

Chief Engineer

STANDARD DETAIL

DOUBLE 1-INCH
METER SETTING

W
5.15a